

# Energy Performance Certificate

## Address of dwelling and other details

FLAT 0/2 87 CORNALEE  
GARDENS  
GLASGOW  
G53 7EP

Dwelling type: Ground-floor flat  
Name of approved organisation: BRE Certification  
Membership number: BREC000200  
Date of certificate: 03 December 2009  
Reference number: 8411-0022-8109-0437-1002  
Total floor area: 45 m<sup>2</sup>  
Main type of heating and fuel: Electric storage heaters

## This dwelling's performance ratings

This dwelling has been assessed using the RdSAP 2005 methodology. Its performance is rated in terms of the energy use per square metre of floor area, energy efficiency based on fuel costs and environmental impact based on carbon dioxide (CO<sub>2</sub>) emissions. CO<sub>2</sub> is a greenhouse gas that contributes to climate change.

### Energy Efficiency Rating

|   | Current                    | Potential   |
|---|----------------------------|---|
| Very energy efficient - lower running costs |                            |   |
| (92 plus) <b>A</b>                          |                            |   |
| (81-91) <b>B</b>                            |                            |   |
| (69-80) <b>C</b>                            |                            |   |
| (55-68) <b>D</b>                            | <b>60</b>                  | <b>62</b>   |
| (39-54) <b>E</b>                            |                            |   |
| (21-38) <b>F</b>                            |                            |   |
| (1-20) <b>G</b>                             |                            |   |
| Not energy efficient - higher running costs |                            |   |
| <b>Scotland</b>                             | EU Directive<br>2002/91/EC |  |

### Environmental Impact (CO<sub>2</sub>) Rating

|   | Current                    | Potential   |
|---|----------------------------|---|
| Very environmentally friendly - lower CO <sub>2</sub> emissions |                            |   |
| (92 plus) <b>A</b>  |                            |   |
| (81-91) <b>B</b>  |                            |   |
| (69-80) <b>C</b>  |                            |   |
| (55-68) <b>D</b>  |                            |   |
| (39-54) <b>E</b>  | <b>53</b>                  | <b>53</b>   |
| (21-38) <b>F</b>  |                            |   |
| (1-20) <b>G</b>   |                            |   |
| Not environmentally friendly - higher CO <sub>2</sub> emissions |                            |   |
| <b>Scotland</b>   | EU Directive<br>2002/91/EC |  |

The energy efficiency rating is a measure of the overall efficiency of a home. The higher the rating the more energy efficient the home is and the lower the fuel bills are likely to be.

The environmental impact rating is a measure of a home's impact on the environment in terms of carbon dioxide (CO<sub>2</sub>) emissions. The higher the rating the less impact it has on the environment.

Approximate current energy use per square metre of floor area: 469 kWh/m<sup>2</sup> per year

Approximate CO<sub>2</sub> emissions: 71 kg/m<sup>2</sup> per year

## Cost effective improvements

Below is a list of lower cost measures that will raise the energy performance of the dwelling to the potential indicated in the tables above. Higher cost measures could also be considered and these are recommended in the attached energy report.

1 Low energy lighting for all fixed outlets

*A full energy report is attached to this certificate*



Information from this EPC may be given to Energy Saving Trust to provide advice to householders on financial help available to improve home energy efficiency.

For advice on how to take action and to find out about offers available to help make your home more energy efficient, call 0800 512 012 or visit [www.energysavingtrust.org.uk](http://www.energysavingtrust.org.uk)

Energy Report



The Energy Performance Certificate and Energy Report for this dwelling were produced following an energy assessment undertaken by a member of BRE Certification. This is an organisation which has been approved by the Scottish Ministers. The certificate has been produced under the Building (Scotland) Amendment Regulations 2006 and a copy of the certificate and this energy report have been lodged on a national register.

Assessor's name: Jackie Brown  
 Company name/trading name: The Glasgow Housing Association  
 Address: Granite House, 177, Trongate, Glasgow, G1 5HF  
 Phone number: 0141 274 6418  
 Fax number: 0141 274 6213  
 E-mail address: jackie.brown@gha.org.uk  
 Related party disclosure:

Estimated energy use, carbon dioxide (CO<sub>2</sub>) emissions and fuel costs of this home

|                          | Current                         | Potential                       |
|--------------------------|---------------------------------|---------------------------------|
| Energy use               | 469 kWh/m <sup>2</sup> per year | 465 kWh/m <sup>2</sup> per year |
| Carbon dioxide emissions | 3.2 tonnes per year             | 3.1 tonnes per year             |
| Lighting                 | £49 per year                    | £25 per year                    |
| Heating                  | £268 per year                   | £274 per year                   |
| Hot water                | £178 per year                   | £178 per year                   |

Based on standardised assumptions about occupancy, heating patterns and geographical location, the above table provides an indication of how much it will cost to provide lighting, heating and hot water to this home. The fuel costs only take into account the cost of fuel and not any associated service, maintenance or safety inspection. This certificate has been provided for comparative purposes only and enables one home to be compared with another. Always check the date the certificate was issued, because fuel prices can increase over time and energy saving recommendations will evolve.

About the building's performance ratings

The ratings on the certificate provide a measure of the building's overall energy efficiency and its environmental impact, calculated in accordance with a national methodology that takes into account factors such as insulation, heating and hot water systems, ventilation and fuels used.

Not all buildings are used in the same way, so energy ratings use 'standard occupancy' assumptions which may be different from the specific way you use your home.

Buildings that are more energy efficient use less energy, save money and help protect the environment. A building with a rating of 100 would cost almost nothing to heat and light and would cause almost no carbon emissions. The potential ratings in the certificate describe how close this building could get to 100 if all the cost effective recommended improvements were implemented.

About the impact of buildings on the environment

One of the biggest contributors to global warming is carbon dioxide. The way we use energy in buildings causes emissions of carbon. The energy we use for heating, lighting and power in homes produces over a quarter of the UK's carbon dioxide emissions and other buildings produce a further one-sixth.

The average household causes about 6 tonnes of carbon dioxide every year. Adopting the recommendations in this report can reduce emissions and protect the environment. You could reduce emissions even more by switching to renewable energy sources. In addition there are many simple everyday measures that will save money, improve comfort and reduce the impact on the environment. Some examples are given at the end of this report.

**Summary of this home's energy performance related features**

The following is an assessment of the key individual elements that have an impact on this home's performance rating. Each element is assessed against the following scale: Very poor / Poor / Average / Good / Very good.

| Elements  | Description                           | Current performance |               |
|---|---------------------------------------|---------------------|---------------|
|   |                                       | Energy Efficiency   | Environmental |
| Walls   | Cavity wall, with external insulation | Good                | Good          |
| Roof  | (another dwelling above)              | -                   | -             |
| Floor   | Suspended, no insulation (assumed)    | -                   | -             |
| Windows   | Fully double glazed                   | Average             | Average       |
| Main heating  | Electric storage heaters              | Poor                | Very poor     |
| Main heating controls                                       | Manual charge control                 | Poor                | Poor          |
| Secondary heating   | None                                  | -                   | -             |
| Hot water   | Electric immersion, off-peak          | Very poor           | Poor          |
| Lighting  | No low energy lighting                | Very poor           | Very poor     |
| <b>Current energy efficiency rating</b>                     |                                       | <b>D 60</b>         |               |
| <b>Current environmental impact (CO<sub>2</sub>) rating</b> |                                       |                     | <b>E 53</b>   |

**Low and zero carbon energy sources**

These are sources of energy (producing or providing electricity or hot water) which emit little or no carbon dioxide into the atmosphere.

There are none applicable to this home.

### Recommended measures to improve this home's energy performance

The measures below are cost effective. The performance ratings after improvement listed below are cumulative, that is they assume the improvements have been installed in the order that they appear in the table. However you should check the conditions in any covenants, warranties or sale contracts, and whether any legal permissions are required such as a building warrant, planning consent or listed building restrictions.

| Lower cost measures<br>(up to £500)                           | Typical savings<br>per year | Performance ratings after improvement |               |
|---|-----------------------------|---------------------------------------|---------------|
|   |                             | Energy efficiency                     | Environmental |
| 1 Low energy lighting for all fixed outlets                   | £18                         | D 62                                  | E 53          |
| <b>Sub-total</b>  | <b>£18</b>                  |                                       |               |
| Higher cost measures  |                             |                                       |               |
| 2 Fan assisted storage heaters and dual immersion cylinder    | £62                         | D 68                                  | D 55          |
| <b>Total</b>  | <b>£80</b>                  |                                       |               |
| <b>Potential energy efficiency rating</b>                     |                             | <b>D 68</b>                           |               |
| <b>Potential environmental impact (CO<sub>2</sub>) rating</b> |                             |                                       | <b>D 55</b>   |

### Further measures to achieve even higher standards

None

Improvements to the energy efficiency and environmental impact ratings will usually be in step with each other. However, they can sometimes diverge because reduced energy costs are not always accompanied by a reduction in carbon dioxide (CO<sub>2</sub>) emissions.

## About the cost effective measures to improve this home's performance ratings

If you are a tenant, before undertaking any work you should check the terms of your lease and obtain approval from your landlord if the lease either requires it, or makes no express provision for such work.

### Lower cost measures (typically up to £500 each)

These measures are relatively inexpensive to install and are worth tackling first. Some of them may be installed as DIY projects. DIY is not always straightforward, and sometimes there are health and safety risks, so take advice before carrying out DIY improvements.

#### 1 Low energy lighting

Replacement of traditional light bulbs with energy saving recommended ones will reduce lighting costs over the lifetime of the bulb, and they last up to 12 times longer than ordinary light bulbs. Also consider selecting low energy light fittings when redecorating; contact the Lighting Association for your nearest stockist of Domestic Energy Efficient Lighting Scheme fittings.

### Higher cost measures (typically over £500 each)

#### 2 Fan assisted storage heaters

Modern storage heaters are smaller and easier to control than the older type in the property. Ask for a quotation for new, fan-assisted heaters with automatic charge control. A dual-immersion cylinder, which can be installed at the same time, will provide cheaper hot water than the system currently installed. Installations should be in accordance with the current regulations covering electrical wiring. Building regulations may apply to this work, so it is best to obtain advice from your local authority building standards department and from a qualified heating engineer. Ask the heating engineer to explain the options, which might also include switching to other forms of electric heating.

## About the further measures to achieve even higher standards

Not applicable

## What can I do today?

Actions that will save money and reduce the impact of your home on the environment include:

- Ensure that you understand the dwelling and how its energy systems are intended to work so as to obtain the maximum benefit in terms of reducing energy use and CO<sub>2</sub> emissions.
- If you have a conservatory or sunroom, avoid heating it in order to use it in cold weather and close doors between the conservatory and dwelling.
- Check that your heating system thermostat is not set too high (in a home, 21°C in the living room is suggested) and use the timer to ensure you only heat the building when necessary.
- Make sure your hot water is not too hot - a cylinder thermostat need not normally be higher than 60°C.
- Turn off lights when not needed and do not leave appliances on standby. Remember not to leave chargers (e.g. for mobile phones) turned on when you are not using them.
- Close your curtains at night to reduce heat escaping through the windows.
- If you're not filling up the washing machine, tumble dryer or dishwasher, use the half-load or economy programme. Minimise the use of tumble dryers and dry clothes outdoors where possible.